


**PROJECT: Example**  
**SAMPLE NO: B-104 (29.0-31.0')**



	INITIAL	16.0 TSF	FINAL
Wet Unit Weight (pcf)	98.2	124.7 (est.)	111.9
Dry Unit Weight (pcf)	59.9	86.3 (est.)	77.4
Moisture Content (%)	63.9	44.6 (est.)	44.6
Void Ratio	1.813	0.949	1.172

<http://www.jaykaytesting.com>

Specific Gravity = 2.70 Sample Diameter (in.) = 2.494 Sample Height (in.) = 0.755	<b>CONSOLIDATION TEST</b>	Sample inundated at 0.125 TSF Sample Description: Dark gray brown elastic SILT Type of Sample: Undisturbed 3" Shelby Tube
---	---------------------------	---