


PROJECT NAME: Example
 LOCATION: Edgewood, Maryland
 PROJECT NUMBER: 12345X.01

GRAVEL		SAND			SILT OR CLAY
COARSE	FINE	COARSE	MEDIUM	FINE	



BORING KEY	SAMPLE NUMBER	DEPTH (ft.)	MC (%)	LL	PL	PI	SOIL DESCRIPTION	GRADATION ANALYSIS	
• S-1	Bulk	---	19.5	32	19	13	Brown lean <i>CLAY</i> with sand (<i>CL</i>) [A-6]	TESTED BY: JMK	DATE: 5-13-09
	On-site material							CHECKED BY: JK	SHEET: 1 of 1
								JAY KAY TESTING Taneytown, Maryland	